



2" – 72"

# J & S Valve®

RESILIENT & METAL SEATED AWWA GATE VALVES

---

## SPECIFICATION

### Metal Seated Solid Wedge Gate Valve

Metal Seated Gate Valve shall be NRS or OS&Y exceed AWWA C500-93 Specifications. The valve body, bonnet, wedge, gland, and hand wheel or nut, shall be constructed of ductile iron. Stem material to be stainless steel. All valves shall have non-asbestos graphite packing. Valve body shall be coated inside and outside as specified. Nuts, bolts, and washers to be stainless steel. End Connections to be flange or mechanical joint. Valves 18" & larger shall be equipped with a bevel or spur gear operator. Valves shall be J & S Valve Series 3000 or engineer's pre-approved equal.

*Ph: (281) 324-3990    ▪    Fax: (281) 324-4595*  
*2323 1<sup>st</sup> Street    ▪    Huffman, TX 77336*  
[www.JandSValve.com](http://www.JandSValve.com)    ▪    [sales@JandSValve.com](mailto:sales@JandSValve.com)